

Maintenance Agreement

Infiltration/Filtration Basin

1. It is the Owner's responsibility to inspect and maintain the permanent stormwater management BMPs through the life of the improvements to the designed requirements.
2. Inspections and maintenance shall occur twice in the first year and at least once per year after
3. Vegetation planted within the basin shall be watered sufficiently for a minimum of 1 year after planting to establish proper growth.
4. The minimum inspection/maintenance requirements are listed below:
 - a. Remove sediment, trash, and debris from basins.
 - b. Scarify bottom of infiltration basin if necessary, to ensure that basins draw down within 48 hours.
 - c. Clean out system when sediment or trash is clogging the discharge orifice.
 - d. Inspect all slopes for rills or washouts. Restore soil and vegetation as necessary.
 - e. Inspect berms and/or swales. Repair any rill or washout and revegetate to ensure areas are protected from erosion.
 - f. Remove and replace dead/diseased vegetation.
5. Snow plowing shall be directed away from all infiltration basins and piled a minimum of 10' from tip of basin.
6. Records of all inspections and maintenance shall be kept by the owner and copies shall be submitted to permitting agencies immediately upon request.
7. Corrective actions as directed by permitting agencies shall be completed within 14 days of their notification or sooner if required.

Owner_____

Signature_____

Dated_____